



Certificate of Compliance

This certificate is issued for the following:

Angle Hose Valves

Model	Product Description	Maximum Working Pressure, psi (kPa)	Nominal Pipe Sizes, in.
SUN-FHV-M	Standard Hose Valve Female NPT x Male NH	300 (2070)	1-1/2, 2-1/2
SUN-FHV-F	Standard Hose Valve Female NPT x Female NPT	300 (2070)	1-1/2, 2-1/2
SUN-FHV-M	Pressure Restricting Hose Valve Female NPT x Male NH	300 (2070)	1-1/2, 2-1/2
SUN-FHV-F	Pressure Restricting Hose Valve Female NPT x Female NPT	300 (2070)	1-1/2, 2-1/2

Prepared for:

Sunpool International Corporation
8A, No. 447, Sec.3
Wen Hsin Road
Taichung, Taiwan ROC.

FM Approvals Class: 1521

Approval Identification: 0003048339

Approval Granted: March 25, 2013

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne", is written over a horizontal line.

Richard B. Dunne
Group Manager -Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group